



CONCRETE THRUST BLOCK OR 2'-8" x 16" SOLID BLOCK CORE UNDER GATE VALVE BETWEEN WATERMAIN AND HYDRANT

NOTE: ALL MECHANICAL JOINTS REQUIRE RETAINER GLANDS

**SECTION A-A**

**HYDRANT ASSEMBLY DETAIL**

NO SCALE